

# Part 573 Safety Recall Report

# 18V-847

**Manufacturer Name :** Altec Industries Inc.

**Submission Date :** NOV 28, 2018

**NHTSA Recall No. :** 18V-847

**Manufacturer Recall No. :** CSN 706



## Manufacturer Information :

**Manufacturer Name :** Altec Industries Inc.

**Address :** 210 Inverness Center Drive  
Birmingham AL 35242

**Company phone :** 205-991-7733

## Population :

**Number of potentially involved :** 38

**Estimated percentage with defect :** 100 %

## Vehicle Information :

**Vehicle 1 :** 2017-2017 Altec AT37/41/48 Aerial Devices

**Vehicle Type :**

**Body Style :**

**Power Train :** NR

**Descriptive Information :** The recall population was determined by a review of production records.

**Production Dates :** MAR 01, 2017 - DEC 30, 2017

**VIN Range 1 : Begin :**

NR

**End :** NR

Not sequential

## Description of Defect :

**Description of the Defect :** Undertorqued or missing fasteners between pedestal and chassis.

**FMVSS 1 :** NR

**FMVSS 2 :** NR

**Description of the Safety Risk :** Loss of stability or separation of the pedestal from the chassis.

**Description of the Cause :** NR

**Identification of Any Warning that can Occur :** The fasteners are subject to periodic inspection requirements intended to detect those that are loose, broken or missing.

## Supplier Identification :

### Component Manufacturer

**Name :** NR

**Address :** NR

NR

**Country :** NR

**Chronology :**

In November 2017 it was noted that torque values for attaching the shear plates to the chassis and rotation bearing fasteners were different than what was published in some local reference material. Testing has been conducted to determine if the applied torque values were sufficient or if a unit recall was required. The field population was monitored and there have been no reported incidents however, it was determined that a field notification was required to correct the affected units

**Description of Remedy :**

Description of Remedy Program : Altec will issue CSN 706 to owners of the affected units requiring them to contact Altec to schedule the repair

How Remedy Component Differs from Recalled Component : N/A

Identify How/When Recall Condition was Corrected in Production : Installation documentation was corrected.

**Recall Schedule :**

Description of Recall Schedule : Altec will issue CSN 706 to owners of the affected units requiring them to contact Altec to schedule the repair.

Planned Dealer Notification Date : JAN 21, 2019 - JAN 22, 2019

Planned Owner Notification Date : JAN 21, 2019 - JAN 22, 2019

\* NR - Not Reported