

Part 573 Safety Recall Report

18V-873

Manufacturer Name : Altec Industries Inc.

Submission Date : DEC 07, 2018

NHTSA Recall No. : 18V-873

Manufacturer Recall No. : CSN 708



Manufacturer Information :

Manufacturer Name : Altec Industries Inc.

Address : 210 Inverness Center Drive
Birmingham AL 35242

Company phone : 205-991-7733

Population :

Number of potentially involved : 156

Estimated percentage with defect : 100 %

Vehicle Information :

Vehicle 1 : 2017-2018 Altec Aerial Devices, Digger Derricks, Service Bodies

Vehicle Type :

Body Style :

Power Train : NR

Descriptive Information : The recall population was determined by reviewing production records to see which units contained the brake lights included on Whelen Engineering recall 18E-063.

Production Dates : NOV 01, 2017 - MAY 30, 2018

VIN Range 1 : Begin :

NR

End : NR

Not sequential

Description of Noncompliance :

Description of the Noncompliance : The brake light may activate if there is transient voltage on the brake input line.

FMVSS 1 : 108 - Lamps, reflective devices, and assoc. Equipment

FMVSS 2 : NR

Description of the Safety Risk : For the recall population, the brake light may activate if there is a transient voltage on the brake input line (e.g., without further brake input), but can be returned to normal operation when a brake input is applied and then removed

Description of the Cause : Transient voltage on the input line

Identification of Any Warning that can Occur : None

Supplier Identification :

Component Manufacturer

Name : Whelen Engineering Co Inc
Address : 51 Winthrop Road
Chester CONNECTICUT 06475
Country : United States

Chronology :

In November 2017 Altec was notified by NHTSA of Whelen Engineering Co, Inc. recall 18E-063. The list of affected part models was reviewed and a list of affected units was determined.

Description of Remedy :

Description of Remedy Program : Altec will issue CSN 708 to owners of the affected units requiring them replace the defective Whelen component
How Remedy Component Differs from Recalled Component : N/A
Identify How/When Recall Condition was Corrected in Production : N/A

Recall Schedule :

Description of Recall Schedule : Altec will issue CSN 708 to owners of the affected units requiring them replace the defective Whelen component
Planned Dealer Notification Date : FEB 06, 2019 - FEB 06, 2019
Planned Owner Notification Date : FEB 06, 2019 - FEB 06, 2019

* NR - Not Reported